

**Pool Fence Criteria:**

	YES	NO
Is there a pool fence separating your pool from neighbouring properties?	<input type="checkbox"/>	<input type="checkbox"/>
Does a pool fence restrict direct access from the house to the pool area?	<input type="checkbox"/>	<input type="checkbox"/>
Is the exterior of the pool fence at least 1.2 meters in height consistently?	<input type="checkbox"/>	<input type="checkbox"/>
Is the bottom of the pool fence uniformly less than 10cm above ground level?	<input type="checkbox"/>	<input type="checkbox"/>
Are vertical or near-vertical members spaced less than 10cm apart?	<input type="checkbox"/>	<input type="checkbox"/>
Are horizontal or near-horizontal fence rails at least 90cm apart?	<input type="checkbox"/>	<input type="checkbox"/>
Is the pool fence well-maintained, without holes or broken members?	<input type="checkbox"/>	<input type="checkbox"/>
Is the pool fence at least 1.2 meters away from any object enabling a child to climb over it, such as BBQs, trees, rocks, shrubs, or deck chairs?	<input type="checkbox"/>	<input type="checkbox"/>
If your pool fence has mesh or perforated material, are the holes no greater than 13mm?	<input type="checkbox"/>	<input type="checkbox"/>

**Doors and Windows:**

	YES	NO
Are all doors and windows leading directly to the pool area child resistant? [child resistant windows are either at least 1.2 meters above the floor, do not open wider than 10cm or have security screens]	<input type="checkbox"/>	<input type="checkbox"/>
If the pool was built post 1991, are there any doors directly leading to the pool area, unless exempt by local council?	<input type="checkbox"/>	<input type="checkbox"/>

**CPR Sign:**

Is there a compliant CPR sign that is easily visible to anyone near the pool?	<input type="checkbox"/>	<input type="checkbox"/>
---	--------------------------	--------------------------

**Pool Registraton:**

Is your pool registered on the QBCC pool register?	<input type="checkbox"/>	<input type="checkbox"/>
--	--------------------------	--------------------------

**Pool Gate Inspector:**

YES NO

Does the pool gate close automatically from any open position?

 

Does the gate latch by itself upon closure?

 

Does the gate swing outward, away from the pool area?

 

Is the gate never propped open or obstructed from automatic closure?

 

Is the latch release at least 1.5 meters above the ground or covered to prevent child access?

 

If gate latch is on the inside, is the latch lever at least 150mm below the top of the fence and covered with a 450mm radius shield on the outside?

 

**Above Ground Pools:**

Are the walls of the above ground pool at least 1.2 meters high uniformly?

 

Is the pool side free from bracing, indents, projections or filtration equipment?

 

Is any ladder and filtration equipment enclosed by a fence with a self closing gate?